






Core identification acc. to VDE 0293-308:2003-01





This identification acc. to HD 308 S2 applies to cables and cords up to 1 kV for fixed and flexible installation.

Multi-core cables

Execution	Number of core	identification
with gn-ye	3	gn-ye/bu/bn 
	4	gn-ye/bn/bk/gy 
(-J) or ..G..	5	gn-ye/bu/bn/bk/gy 

Examples:



NYM-J, NYY-J, H07RN-F,
H03VV-F, H05VV-F etc. with
protective conductor

Execution	Number of core	identification
without gn-ye	2	bu/bn 
	3	bn/bk/gy 
(-O) or ..X..	4	bu/bn/bk/gy 
	5	bu/bn/bk/gy/bk 

Examples:

NYM-O, NYY-O, NYCWY,
NYCY, H07RN-F, H03VV-F,
H05VV-F etc. without
protective conductor

Single-core cables

Protective conductor	1	gn-ye 
Neutral conductor	1	bu 
Phase conductor	1	bn/bk/gy 