

Approval Number: 2002513  
Test Report: M106981A & B



23<sup>rd</sup> September 2020

Aristoncavi SpA  
Via Eninaudi 8,  
36040 Brendola (VI),  
Italy

Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**RUBBERS - ETHYLENE PROPYLENE DIENE MONOMER (EPDM) - COMPONENTS.**

**5360**

'Drincable 800'. Blue coloured, extruded, cylindrical shaped EPDM cable. The EPDM outer sheath is the water contact part and has a shore hardness of 50 and tested in-radius size of between 0.6mm & 1.8mm. For use with water up to 23°C.

**APPROVAL NUMBER: 2002513**

**APPROVAL HOLDER: ARISTONCAVI SPA**

The Scheme reserves the right to review approval.  
Approval 2002513 is valid between February 2020 and February 2025

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in dark ink, appearing to read 'J Furnival', written in a cursive style.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme